

3 Convenient Setting Features

For Stable Detection Regardless of Received Light Intensity Changed due to Dust or Dirt

DPC Function
Use of the DPC function with through-beam model or regressive reflection model is recommended.

The DPC indicator turns ON when the DPC function is effective.

Smart Tuning → Run → SET mode → Select → DPC Function ON

When smart tuning is in error/maximum sensitivity tuning is executed/the 1st point of the position tuning is smaller/area detection mode, the DPC function is disabled.

Initializing Settings

Setting Reset Initialize all settings to the factory-set defaults.

Saving/Reading Settings

User Save Function/User Reset Function

User Save Function → [SAuE] → [SAuE no] → [SAuE YES]

User Reset Function → [rSt] → [rSt no] → [rSt USEr]

Preventing Malfunction

Key Lock Function Disables all the button operations.

Enable/Cancel (The same procedure)

4 Maintenance

4-1 Troubleshooting

Problem	Cause	Remedy
Nothing is shown on the indication.	No power supplied or the cable broken.	Check the connection of the connector between the Communication Unit and Amplifier.
Nothing is shown on the digital indication.	Eco mode is ON.	Turn OFF Eco mode. *1
Sensing/Detection not possible despite the minimum threshold level.	Detection set to a small light level mode Dust or dirt influences.	Setting GIGA Mode increases emission power and light intensity. *1
The OUT indicator blinking.	Mutual interference or other reason.	Check the Amplifier Units mounted in a group and turn ON the power again. *2
Incident light level displayed in a negative value.	The zero reset function is enabled.	Cancel the zero reset function. *3
LED is not emitted.	Is an LD-OFF command sent from the Communication Unit?	Check whether the LD-OFF command is sent from the Communication Unit.
Lost tracking of the settings made.	-	Reset the settings. *3
The light intensity level display changes.	Affected by dust or dirt, temperature change, vibration, etc.	Use of the DPC function makes the light intensity level display stable. *3

*1 Refer to "⑤ Detailed Settings". *2 Refer to "①-3 Mounting Amplifier Unit" *3 Refer to "③ Convenient Setting Features"

For information on troubleshooting with Communication Unit, refer to the User's Manual provided with the Communication Unit.

Error Display

Error Name / Display	Cause	Remedy
DPC Error *1 20004000	The incident light level has deteriorated due to dust or dirt.	Wipe the dust off the Fiber Unit detection surface or other relevant areas and recover the original incident light level. Then, perform Smart Tuning. *2
EEPROM time-out error E-rE 01	Failed internal data read/out.	Turn ON the power again. Reset the settings if the error is not corrected. *3
EEPROM checksum error E-rE 02	Failed internal data read/out.	Turn ON the power again. Reset the settings if the error is not corrected. *3
Lock ON LoL on	The key lock function enabled.	Cancel the key lock function. *3
Load short circuit detection error E-St	Over current flowing to the control output.	Check the connection of the connector between the Communication Unit and Amplifier.

*1 The DPC indicator blinks. *2 Refer to "②-3 Smart Tuning" *3 Refer to "③ Convenient Setting Features"

Returning Received Light Intensity Display to "0"

Zero Reset Function

Enable: Press and hold the MODE button for 3 seconds or longer. The display shows '2000 0'. Executing DPC function/smart tuning releases the zero reset.

Cancel: Press and hold the MODE button for 3 seconds or longer. The display shows '6000 4000'. The lower threshold limit is -1999.

For Output When Received Light Intensity is Within the Area

Area Detection Mode

- Select (Setting Mode) - [OUT1 Mode] - [Area Detection Mode]. Pressing the [MODE] button for 3 seconds or longer exits the SET mode.
- Press the [MODE] button in [Measurement Mode] to display "OUT1 HIGH" and "OUT1 LOW". Green digital indicator shows HIGH and LOW.
- Provide Smart Tuning to each of HIGH/LOW thresholds by pressing the [TUNE] button.

In tuning by percent, the thresholds are set as follows:
 HIGH: Received light intensity in 3. × Absolute value of percent tuning level
 LOW: Received light intensity in 3. × Absolute value of percent tuning level

Checking Received Light Intensity When Workpiece Passes at High Speed

Change finder

- Select (Setting Mode) → [Digital Display] to set [diSP CFdr].
- Pressing the [MODE] button for 3 seconds or longer exits the SET mode.
- Let the workpiece pass.
- Displays and retains the light intensity (maximum/minimum value) in white digital for 0.5 seconds when the workpiece passes.

The change finder is not displayed in (Setting Mode). If the product is the reflective type, the local maximum value is displayed by setting light-on. If it is the through-beam type, the local minimum value is displayed by setting dark-on.

Determining If Workpiece is Detectable

Solution Viewer

- Press both the [MODE] and [L/D] buttons for at least 3 seconds to set to [SoLU on]. To release the setting, press the [MODE] and [L/D] buttons for at least 3 seconds to set to [SoLU off].
- Let the workpiece pass.
- Passing time and light amount difference are displayed.
- Press the [MODE] and [L/D] buttons at the same time for at least 3 seconds to exit setting mode.

5 Detailed Settings

Hold [MODE] button for 3 seconds or longer to enter SET mode. The OUT Selection Indicators show items for Output1/Output 2 individually for each output.

SET mode provides the following function settings. The initial display shown after transition from one function to another represents the factory default.

- Function Selection** Enabling 6 to 14
Basic setting: [FUNc dFLt] → Detailed setting: [FUNc oPt]
- Detection Function** Changing Light Level and Response Time
HS High-speed Mode: [HS 500] → STND Standard Mode: [Stnd 500] → GIGA Giga Mode: [GIGA 4000] → SHS Super High-speed Mode: [SHS 125]
- DPC Function** Stable Detection Regardless of Incident Light Level Change
DPC OFF: [dPC off] → DPC ON: [dPC on]
- Timer Function** Setting Output Timer (Two outputs are displayed)
After pressing the [MODE] button, Use [MODE] button to set the time. (1 to 9999ms in 1ms steps; the initial value: 10ms Error range: 0.1ms)
(a) Off-delay Timer: [oFFd 10] (b) On-delay Timer: [on-d 10] (c) One shot: [SHot 10] (d) On Off-delay Timer: [onoF ---]
- Power Tuning Level** Changing the Target Incident Light Level (Power Tuning Level)
Use [MODE] button to set the power tuning level. (100 to 9999 in 1 steps; the initial value: 9999)
Reference value: [P-Lu 9999]
- BANK Switching** Set values are saved for each configured bank.
BANK1: [bAnk 1] → BANK2: [bAnk 2] → BANK3: [bAnk 3] → BANK4: [bAnk 4]
- Power Tuning ON/OFF Setting** To Turn ON/OFF the Light Amount Adjustment at Tuning
Power tuning adjustment ON: [PtUn on] → Power tuning adjustment OFF: [PtUn off] → Power tuning adjustment during power-up: [PtUn Pon]
- Percentage Tuning** Detecting Transparent or Microscopic object (Two outputs are displayed)
Percentage tuning OFF: [PEr off] → Percentage tuning ON: [PEr on]
Press [MODE] button in [PEr on] menu, then use [MODE] button to set the percentage tuning level. (-99% to 99% in 1% steps; the initial value: -6%)
- Output 1 Mode** Output mode for the output 1 is changed.
If the "dFF" menu is selected, response time can be set up continuously.
1: 250 μs, 2: 500 μs, 3: 1 ms, 4: 10 ms, 5: 100 ms
Normal detection mode: [oUt Std] → Area detection mode: [oUt ArER] → Differential detection mode: [oUt dFF]

*** Detecting Incident Light Level Change**
Detects if the absolute value of the incident light level change of the set response time is larger than the threshold value. The display shows the change of the incident light level of the set response time in white. When the differential function is enabled, the detection function setting is disabled. Smart tunings except power tuning are disabled.

- Output 2 Mode** Output mode for the output 2 is changed.
Normal detection mode: [oUt Std] → Alarm output mode: [oUt ALrn] → Error output mode: [oUt Err] → Differential detection mode: [oUt dFF]
- Digital Display** Changing Digital Display in RUN Mode for Specific Purpose
Threshold Receiving light amount: [diSP Std] → (a) To see the reserve of the light intensity level for the threshold: [diSP PEr] → (b) To set the threshold with a microscopic object or fast-moving object easy to follow display: [diSP P-b] → (c) To see the intuitive and easy to follow display: [diSP CFdr] → (d) To see the received light intensity when workpiece passes at high speed: [diSP CH] → (e) To know the CH number when two or more units connected: [diSP PEAR] → (f) To adjust the beam: [diSP 9999]
- Inverted Display** Mounting Amplifier in Inverted Direction
Normal: [rEu off] → Reverse: [uo n3]
- Eco Function** Saving Power Consumption
Eco on: [ECo off] → Eco function ON: [ECo on] → Eco function LO: [ECo Lo]
- Hysteresis width** (Two outputs are displayed)
Standard setting: [HStd 37] → User setting: [HUSr 37]

Set the hysteresis width by initial value. Hysteresis width is provided for threshold to prevent the judgment output from becoming unstable near the boundaries.
The hysteresis width can be set by pressing the [MODE] button in the menu of "HUSr" and then pressing the [MODE] button. (0 to 9999, increments of 1)
Be sure to check the stability of outputs as there is a possibility of chattering.

Suitability for Use

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM. See also Product catalog for Warranty and Limitation of Liability.

OMRON Corporation Industrial Automation Company
Tokyo, JAPAN Contact: www.ia.omron.com

Regional Headquarters
OMRON EUROPE B.V.
Sensor Business Unit
Carl-Benz-Str. 4, D-71154 Nufringen, Germany
Tel: (49) 7032-811-0/Fax: (49) 7032-811-199

OMRON ELECTRONICS LLC
2895 Greensport Parkway, Suite 200
Hoffman Estates, IL 60169 U.S.A.
Tel: (1) 847-843-7900/Fax: (1) 847-843-7787

OMRON ASIA PACIFIC PTE. LTD.
No. 438A Alexandra Road # 05-05/08 (Lobby 2),
Alexandra Technopark,
Singapore 119967
Tel: (65) 6835-3011/Fax: (65) 6835-2711

OMRON (CHINA) CO., LTD.
Room 2211, Bank of China Tower,
200 Yin Cheng Zhong Road,
FuDong New Area, Shanghai, 200120, China
Tel: (86) 21-5037-2222/Fax: (86) 21-5037-2200

Oct, 2014

3 便捷设定

随时修正因粉尘导致的受光量不稳定

● DPC功能
DPC功能推荐在对射型/回归反射型产品上使用。

智能调整 实行 设定模式 选择 开启DPC功能

当智能调整出错/开启最大灵敏度调整/定位调整第一点过小/开启区域检测模式的时候，DPC功能无效。

设定初始化

● 设定初始化 把设定状态初始化，恢复出厂时状态。

同时长按3秒以上

保存/读取设定

● 保存/读取设定

用户保存 (保存设定) → [SAUE] → [SAUE no] → [SAUE YES]

用户复位 (读取设定) → [rSt] → [rSt no] → [rSt USER]

防止误操作

● 按键锁定 关闭所有按键的操作功能。

开启/解除 (步骤相同)

4 维修保养

4-1 故障排除

故障	原因	对策
画面无任何显示	未接通电源断线	请确认通信单元和放大器的连接状况
没有任何数字显示	开启了节能功能	请关闭节能功能*1
阈值调整至最小也无法感应和检测	检测模式设定为了光量弱的检测模式 受到了粉尘或污垢影响	若设定至高精度模式，可以让投光量增强，受光量显示值增大*1
[输出指示灯] 闪烁	受到了相互干涉等影响	请确认放大器的连接状态、再次接通电源*2
受光量显示值为负值	开启了显示值归零功能	请关闭显示值归零功能*3
LED无投光	通信单元未发送LD-OFF指令	请确认通信单元是否已发送LD-OFF指令
画面上显示“LoFF”	-	-
设定状态不明	-	请执行设定初始化*3
受光量显示变动	受到灰尘或污垢·温度变化·振动等影响。	若使用DPC功能，受光量显示即可稳定。*3

*1 ⑤详细设定 *2 1-3放大器的安装 *3 ③便捷设定

和通信单元发生故障时，请参考通信单元的《用户操作手册》。

● 维修保养的错误代码

错误名/显示	原因	对策
DPC错误*1 2000 4000	受到了粉尘或污垢影响，受光量低下	请擦拭光纤头部，还原受光量，并再次智能调整*2
EEPROM超时错误 E-nE 01	读取/写入内部数据失败	请重新接通电源 若仍未恢复，请执行设定初始化*3
EEPROM SUM值校对错误 E-nE 02	读取/写入内部数据失败	请重新接通电源 若仍未恢复，请执行设定初始化*3
LOCK ON LoL ON	开启了按键锁定功能	请关闭按键锁定功能*3
负荷短路检测错误 E-St	控制输出上有过电流	请确认通信单元和放大器的连接状况

*1 [DPC指示灯] 闪烁 *2 2-3 智能调整 *3 ③ 便捷设定

受光量显示值归零

● 显示值归零
开启 解除

仅在一定受光量范围内有输出

● 区域检测模式

- 选择[设定模式] → [输出1模式] → [区域检测模式]。按[MODE]键3秒即可退出设定模式。
- 在[检测模式]下短按[MODE]键，切换OUT1 HIGH和OUT1 LOW的设定界面，绿色数字会分别显示HIGH和LOW字样。
- 通过[S.TUNE]键分别设定HIGH和LOW的阈值。

开启百分比调整功能时，阈值被设定如下：
HIGH: 步骤3时的受光量 × 步骤3时的受光量 × 百分比调整值的绝对值
LOW: 步骤3时的受光量 - 步骤3时的受光量 × 百分比调整值的绝对值

工件高速通过时的受光量显示

● 受光量停留显示

- 在[设定模式] → [数字显示] 中选择[dISP CfdR]。
- 长按[MODE]键3秒以上，退出设定模式。
- 让工件通过。
- 通过时的受光量以白色数字的形式持续显示0.5秒(最大值/最小值)。

判断工件可否检测

● 检测难易度测试

- 同时按下[MODE]和[L/D]键3秒以上，设定为[SoLU on]，开启该功能。相同操作可解除该功能，设定为[SoLU off]。
- 让工件通过。
- 显示通过时间/受光量差值。
- 持续同时按[MODE]+[L/D]按钮3秒以上即可切换设定模式。

4-2 额定/规格

型号	E3NX-FA0	E3NX-FAH0
控制输出数	2	
连接方式	通信单元专用连接型	
对应通信单元	E3NW 系列通信单元、E3NW-DS	
光源 (发光波长)	红色 4 元素发光二极管 (625nm)	红外发光二极管 (870nm)
电源电压	DC10 ~ 30V (含波动 (p-p) 10%) (通过连接器, 由通信单元供给)	
消耗电力	电源电压 24V 时 常规模式: 920mW 以下 (消耗电流 38mA 以下) 节能模式 ON: 680mW 以下 (消耗电流 28mA 以下) 节能功能 LO: 800mW 以下 (消耗电流 33mA 以下)	电源电压 24V 时 常规模式: 1080mW 以下 (消耗电流 45mA 以下) 节能模式 ON: 920mW 以下 (消耗电流 38mA 以下) 节能功能 LO: 1020mW 以下 (消耗电流 42mA 以下)
控制输出	请参考通信单元的规格	
保护电路	电源逆接保护、输出短路保护	
最多连接台数	30 台	
相互干涉防止台数 *1	10 台 (超高速模式 (SHS) 下无法实现相互干涉防止功能)	
存档切换设定	可从 BANK1 ~ 4 中选择	
APC 功能 (自动投光量控制)	有 (永久开启)	
使用环境照度	受光面光度 白炽灯 : 20,000lx 以下、太阳光 : 30,000lx 以下 动作状态 : (1~2 台连接) 0°C ~ +55°C、(3~10 台连接) 0°C ~ +50°C、 (11~16 台连接) 0°C ~ +45°C、(17~30 台连接) 0°C ~ +40°C 保存状态 : -30°C ~ +70°C (无结冰凝露)	
使用环境温度 *2	运行 · 保存时: 在上述环境温度范围内, 各 35 ~ 85%RH (但是, 不得有凝露)	
高度	2000m 以下	
设置环境	污损度 3 (基于 IEC60947-1)	
绝缘电阻	20MΩ 以上 (使用 DC500V 兆欧表)	
耐电压	AC1,000V、50/60Hz、1min	
振动 (耐久)	10 ~ 55Hz、双振幅 1.5mm、XYZ 各方向 2h	
冲击 (耐久)	150m/s ² 、XYZ 各方向 3 次	
重量 (捆包/净重)	约 65g / 约 25g	
材质	外壳、保护罩: 聚碳酸酯 (PC); 导线外被: PVC	

*1. 相互干涉防止台数不会因为传感器设定状态发生变化。
型号 E3NX、型号 E3NC 的防止相互干扰台数中最小的台数。确认各型号的防止相互干扰台数和响应速度。
*2. 连接台数达 11 台以上时，环境温度范围为 50°C 以下。

5 详细设定

长按 [MODE] 键 3 秒以上进入设定模式。
设定模式下可设置以下功能。
在主轴上显示的功能为出厂时的设定。

根据 [输出选择指示灯]，可对输出 1/2 分别进行设定。

- 功能选择 (详细设定可设置第 6~14 项功能)**
基本设定: FUnC dFLt → FUnC oPt
- 检测模式 (修改光量强度和响应时间)**
HS 高速模式: HS 500 → Stnd 500 → G.GA 4000 → SHS 125
SHS 超高速模式
- DPC 功能 (随时修正受光量显示值、稳定检测)**
DPC 功能关闭: dPC off → dPC on
- 输出延时功能 (设定输出的延长时间。高性能型可分别设定)**
先按 [MODE] 键，再按 [UP/DOWN] 键设定延时时间。
(范围 1~9999ms、刻度 1ms、初始值 10ms、错误 0.1ms)
a) OFF 延时: aOFFd 10
b) ON 延时: on-d 10
c) 单触发: SHot 10
d) ON+OFF 延时: onof-----
- 光量调整值 (设定受光量目标值)**
P-Lu 9999 → P-Lu 37
- 存档切换 (保存每个存档的设定值)**
bAnL 1 → bAnL 2, bAnL 3, bAnL 4
- 光亮调整功能关闭设定 (防止因智能调整而做出的光量调整)**
PtUn on → PtUn off → PtUn Pon
- 百分比调整功能关闭设定 (检测透明或微小物体。高性能型可分别设定)**
PEr off → PEr on
- 输出 1 模式 (修改输出 1 模式)**
out Std → out ArEr → out dFF

- 输出 2 模式 (修改输出 2 模式)**
out Std → out ALrn → out Err → out dFF
- 数字显示 (根据不同使用目的，修改传感器检测模式时的数字方式)**
dISP Std → dISP PEr → dISP P-b → dISP bAr → dISP CfdR → dISP CH → dISP PPERL
- 反转数显 (反向安装放大器)**
rEu off → rEu on
- 节能功能 (减少电力消耗)**
ECo off → ECo on → ECo Lo
- 迟滞幅度设定 (修改输出 2 模式)**
HStd 37 → HUSr 37

长按 3 秒 [MODE] 键，回到检测模式

承诺事项

本公司产品是作为工业通用品而设计制造的。因此，不适用于以下用途，当公司产品被使用于以下用途时，本公司不做任何保证。但若是本公司特意为以下用途而设计、或有过特别协商的情况下，可以用于以下用途。

- 需要高度安全性的用途(例: 用于原子能控制设备、焚烧设备、航空·宇宙设备、铁道设备、升降设备、娱乐设备、医用器、安全装置、或其他可能危及到生命·人身安全的用途)
- 需要高可靠性的用途(例: 煤气·水力·电力等的供给系统、24小时连续运转系统、决策系统、或其他牵涉到权利·财产的用途)
- 苛刻条件或环境下的用途(例: 室外设备、易受化学污染的设备、易受电磁干扰的设备、易受震动·冲击的设备等)
- 产品手册里未记载的条件或环境下的用途

*除上述a)~d)的记载事项，本产品手册等记载的商品不适用于机动车(包括两轮车，以下相同)。请勿搭载于机动车上使用。机动车搭载用商品请咨询本公司销售人员。
*以上是适用条件的一部分。详情请参阅记载于本公司最新版的综合产品目录、使用手册上的保证·免责声明后再使用。

■ 技术咨询

欧姆龙 (中国) 有限公司
地址: 中国上海市浦东新区银城中路200号
中银大厦2211室
电话: (86) 21-5037-2222
技术咨询热线: 400-820-4535
网址: http://www.fa.omron.com.cn

© 2013年7月